certificate	
no.	**BAU 21152**
dated	2021-06-28

DGUV Test
Prüf- und Zertifizierungsstelle
Fachbereich Bauwesen

Translation In any case, the German original shall prevail.

EuroTest Certificate

Name and address of the holder of the certificate: (customer)	LTW Tiefbauvertriebs GmbH Holter Weg 11 41836 Hückelhoven GERMANY
Product designation:	**Trench-shoring system, made of steel**
Type:	Shoring box VB 100
Testing based on:	EN 13331-2:2002 EN 13331-1:2002 DIN 4124:2012
Test report:	
Further details:	Panel length up to 4,00 m Panel heights up to 2,92 m Rated value panel M = 79,9 kNm/m Rated value part M = 141,8 kNm Additional certificate to number: 16109-ET. Intended Purpose According to assembly instructions of manufacturer. The permissible earth pressure is to be taken from manufacturer´s assembly instructions as a function of the system size. The manufacturer is also Certificate holder.

The type tested complies with the test basis specified above.
The holder of the certificate is entitled to affix the ET-mark shown overleaf to the products complying with the type tested.

The present certificate including the right to affix the ET-mark is valid until: **2026-06-26**

Further provisions concerning the validity, the extension of the validity and other conditions are laid down in the Rules of Procedure for Testing and Certification.

Dipl.-Ing. (FH) Franz Welsch
Deputy Head of Testing and Certification Body

Prüf- und Zertifizierungsstelle · DGUV Test · Fachbereich BAU

Deutsche Gesetzliche Unfallversicherung (DGUV) e. V.
Spitzenverband der gewerblichen Berufsgenossenschaften
und der Unfallversicherungsträger der öffentlichen Hand
Vereinsregister-Nr. VR 751 B, Amtsgericht Charlottenburg

DGUV Test Prüf- und Zertifizierungsstelle
Fachbereich Bauwesen
Am Knie 6 • 81241 München • Deutschland
Telefon: +49 (0) 89 88 97-8 58 • Fax: +49 (0) 800 668 6688 38470

certificate
no. **BAU 25190**
dated 2025-12-04

DGUV Test
Prüf- und Zertifizierungsstelle
Fachbereich Bauwesen

Translation In any case, the German original shall prevail.

EuroTest Certificate

Name and address of the holder of the certificate: (customer)	LTW Tiefbauvertriebs GmbH Holter Weg 11 41836 Hückelhoven GERMANY
Product designation:	**Shoring strut, infinitely adjustable**
Type:	Shoring strut ST 340
Testing based on:	GS-BAU-24:2024-07
Test report:	2025 0097 04
Further details:	The strut length may only be increased by means of a single extension piece. Subsequent certificate to number BAU 20263. The manufacturer is also Certificate holder.

The type tested complies with the test basis specified above.
The holder of the certificate is entitled to affix the ET-mark shown overleaf to the products complying with the type tested.
The present certificate including the right to affix the ET-mark is valid until: **2030-11-30**

Further provisions concerning the validity, the extension of the validity and other conditions are laid down in the Rules of Procedure for Testing and Certification.

Dipl.-Ing. (FH) Franz Welsch
Deputy Head of Certification Body

Prüf- und Zertifizierungsstelle DGUV Test Fachbereich BAU

Deutsche Gesetzliche Unfallversicherung e. V. (DGUV)
Spitzenverband der gewerblichen Berufsgenossenschaften
und der Unfallversicherungsträger der öffentlichen Hand
Vereinsregister-Nr. VR 751 B, Amtsgericht Charlottenburg

DGUV Test Prüf- und Zertifizierungsstelle
Fachbereich Bauwesen
Zwengenberger Straße 68 • 42781 Haan • Deutschland
Telefon: +49 89 8897-858 • Fax: +49 800 6686688-38470