certificate
no. **BAU 26136**
dated 2026-07-07

DGUV Test
Prüf- und Zertifizierungsstelle
Fachbereich Bauwesen

Translation In any case, the German original shall prevail.

Test Certificate

Name and address of the holder of the certificate (customer):	LTW Tiefbauvertriebs GmbH Holter Weg 11 41836 Hückelhoven-Brachelen GERMANY
Subject of the test:	**Trench-shoring-system, made of steel**
Type:	Shoring Box VB 100
Testing based on:	GS-BAU-24:2024-07 EN 13331-1:2002, EN 13331-2:2002 DIN 4124:2012
Test Report:	2026 0067 01
Further details:	Panel lengths up to 4.00 m Base panel height up to 2.92 m Design value for panel M = 79.9 kNm/m Design value for side panel M = 141.8 kNm Intended Use: As specified in the manufacturer's instructions for use and operation. Maximum Permissible Earth Pressure: See the instructions for use and operation. Subsequent certificate to number BAU 21152. The manufacturer is also Certificate holder.

The subject tested complies with the test basis specified above.
The present certificate is valid until: **2031-06-26**
The test certificate is not entitled to use a test mark.
Further provisions concerning the validity, the extension of the validity and other conditions are laid down in the Rules of Procedure for Testing and Certification.

Dipl.-Ing. (FH) Franz Welsch
Deputy Head of Certification Body

Prüf- und Zertifizierungsstelle · DGUV Test · Fachbereich BAU

Deutsche Gesetzliche Unfallversicherung e. V. (DGUV)
Spitzenverband der gewerblichen Berufsgenossenschaften
und der Unfallversicherungsträger der öffentlichen Hand
Vereinsregister-Nr. VR 751 B, Amtsgericht Charlottenburg

DGUV Test Prüf- und Zertifizierungsstelle
Fachbereich Bauwesen
Zwengenberger Straße 68 • 42781 Haan • Deutschland
Telefon: +49 89 8897-858 • Fax: +49 800 6686688-38470

certificate
no. **BAU 25190**
dated 2025-12-04

DGUV Test
Prüf- und Zertifizierungsstelle
Fachbereich Bauwesen

Translation In any case, the German original shall prevail.

EuroTest Certificate

Name and address of the holder of the certificate: (customer)	LTW Tiefbauvertriebs GmbH Holter Weg 11 41836 Hückelhoven GERMANY
Product designation:	**Shoring strut, infinitely adjustable**
Type:	Shoring strut ST 340
Testing based on:	GS-BAU-24:2024-07
Test report:	2025 0097 04
Further details:	The strut length may only be increased by means of a single extension piece. Subsequent certificate to number BAU 20263. The manufacturer is also Certificate holder.

The type tested complies with the test basis specified above.
The holder of the certificate is entitled to affix the ET-mark shown overleaf to the products complying with the type tested.
The present certificate including the right to affix the ET-mark is valid until: **2030-11-30**

Further provisions concerning the validity, the extension of the validity and other conditions are laid down in the Rules of Procedure for Testing and Certification.

Dipl.-Ing. (FH) Franz Welsch
Deputy Head of Certification Body

Prüf- und Zertifizierungsstelle DGUV Test Fachbereich BAU

Deutsche Gesetzliche Unfallversicherung e. V. (DGUV)
Spitzenverband der gewerblichen Berufsgenossenschaften
und der Unfallversicherungsträger der öffentlichen Hand
Vereinsregister-Nr. VR 751 B, Amtsgericht Charlottenburg

DGUV Test Prüf- und Zertifizierungsstelle
Fachbereich Bauwesen
Zwengenberger Straße 68 • 42781 Haan • Deutschland
Telefon: +49 89 8897-858 • Fax: +49 800 6686688-38470